

Out-of-bounds Read vulnerability in CX-Programmer

Release date: April 22, 2024

OMRON Corporation

■ Overview

Out-of-bounds Read vulnerability (CWE-125) was found in CX-Programmer. Attackers may be able to read sensitive information or cause an application crash by abusing this vulnerability.

The products and versions affected by these vulnerabilities, mitigation and protection measures are shown below. Make sure to implement these recommended mitigations and protections to minimize the risk of exploitation of these vulnerabilities. Moreover, to ensure that customers use our products with confidence, the security enhanced countermeasure version of each product will be prepared. Please check countermeasure shown below in this document and implement appropriate countermeasure.

■ Affected products

Affected products and versions are below.

Product series	Model	Version
CX-Programmer	Included in CX-One CXONE-AL[][]D-V4	Ver. 9.81 or lower

Refer to "About CX-Programmer" in "Technical Specifications" of the manual below to check the target product version.

- CX-Programmer Ver.9.[] OPERATION MANUAL (W446)

■ Description

CX-Programmer has the vulnerability known as Out-of-bounds Read (CWE-125), which allows attackers to read sensitive information or cause an application crash.

■ CVSS Scores

Out-of-bounds Read (CWE-125)

CVE-2024-31412

CVSS:3.1/AV:L/AC:L/PR:N/UI:R/S:U/C:H/I:H/A:H Base Score: 7.8

■ Countermeasure

Update your CX-Programmer to the countermeasure version to fix the vulnerability. The countermeasure version and respective release date for each product is shown in the table below.

Product series	Model	Version to be released	Scheduled release
CX-Programmer	Included in CX-One CXONE-AL[[]]D-V4	Ver. 9.82 or higher	April 22, 2024

For information on how to obtain and update the countermeasure version of the product, please contact our sales representative or distributor. You can update CX-One to the latest versions using the installed Omron Automation Software AutoUpdate tool.

■ Mitigations and Protections

OMRON recommends that customers take the following mitigation measures to minimize the risk of exploitation of these vulnerabilities.

1. Anti-virus protection

Protect any PC with access to the control system against malware and ensure installation and maintenance of up-to-date commercial grade anti-virus software protection.

2. Security measures to prevent unauthorized access

- Minimize connection of control systems and equipment to open networks, so that untrusted devices will be unable to access them.
- Implement firewalls (by shutting down unused communications ports, limiting communications hosts) and isolate them from the IT network.
- Use a virtual private network (VPN) for remote access to control systems and equipment.
- Use strong passwords and change them frequently.
- Install physical controls so that only authorized personnel can access control systems and equipment.
- Scan virus to ensure safety of any USB drives or similar devices before connecting them to systems and devices.
- Enforce multifactor authentication to all devices with remote access to control systems and equipment whenever possible.

3. Data input and output protection

Validation processing such as backup and range check to cope with unintentional modification of input/output data to control systems and devices.

4. Data recovery

Periodical data backup and maintenance to prepare for data loss.

■ Contact information

Please contact our sales office or distributors.

https://www.ia.omron.com/global_network/index.html

■ Acknowledgment

Michael Heinzl reported this vulnerability through JPCERT/CC.

Thanks to Michael Heinzl for finding and reporting the vulnerability.

■ Update history

- April 22, 2024: New Release